

FYRAXTM
Fire Equipments



JAS-ANZ



CHIRAG INDUSTRIES (A N ISO 9001:2008 CERTIFIED COMPANY)

Works: Plot No: 52,53,54 HSIIDC Ind Estate, Murthal

Dist: Sonipat, Haryana, India Ph: 0130-248-3257 email: chiragindustries2005@yahoo.com

DATE :- 20/04/2023

TEST AND WARRANTY CERTIFICATE

TEST CERTIFICATE FOR	6-KG ABC TYPE FIRE EXTINGUISHERS
HYDRO TEST	35KGF/CM2
MANUFACTURER	CHIRAG INDUSTRIES, HARYANA (INDIA)
NAME OF BUILDING	DEBI COLLEGE OF PHARMACY
OWNER	DEBI COLLEGE OF PHARMACY
ADDRESS	VILL+P.O-TELAKPUR,PIN-741164,DIST-NADIA(W.B)
TESTED BY	CHIRAG INDUSTRIES, HARYANA (INDIA)
TESTING DATE	15/04/2023
FIRE RATING	2A & 55B
QUANTITY	6- NOS.
SERIAL NUMBER	BEARING SERIAL NO (15253 TO 15840) (15841 TO 17098) (18385 TO 18800)

DECLARATION:

The above mentioned goods are warranted against defect in material and workmanship under normal use. The warranty is limited to a period of THIRTY SIX MONTHS FROM THE DATE OF SUPPLY whichever is earlier. The company's obligation shall be limited to rectifying, repairing or replace defective parts EX- Factory, provided the purchase has given immediate written notice upon the discovery of such defect. The company will be automatically relieved of its obligation in case the unit is open or any changes/repairs are made without its prior approval within the guarantee period. These warranty any and every other obligation for loss or damage direct or consequential or for any accident resulting the defective and faulty workmanship

Handwritten signature
Secretary
Educational Research Council,
Vill + P.O.- Telakpur, Dt. Nadia,
W.B.



FOR CHIRAG INDUSTRIES

Authorized Signatory

DAS FIRE AND LIFE SAFETY



Government Of West Bengal
Office Of The Divisional Fire Officer, Nadia
West Bengal Fire & Emergency Services
Azad Hind Sarak, P.O.:- Ghurni, P.S.:- Kotwali, Pin :- 741103

Memo no.:FSR/0125186231000377

Date: 12-11-2023

From:

Divisional Fire Officer, Nadia
West Bengal Fire & Emergency Services

To: DEBI COLLEGE OF PHARMACY
Tilakpur, Chapra, Nadia, W.B, Pin- 741164

Sub: Fire Safety Certificate for an existing G+III storied Educational building under group of Educational Institution in the name & style Debi College of Pharmacy, at the premises No. Dag No. 1786(P), Khatian No. RS 20803, Mouza- Mahatpur, JL No. 100, under Mahatpur Gram Panchayat, Vill:- Tilakpur, Post:- Tilakpur, PS:- Chapra, Dist:- Nadia, Pin- 741164, West Bengal.

This is in reference to your application no. 0125189231000142 dated 01-11-2023 regarding the Fire Safety Certificate for an existing G+III storied Educational building under group of Educational Institution in the name & style " Bhaktabala B. Ed. College ", at the premises No. Dag No. 1786(P), Khatian No. RS 20803, Mouza- Mahatpur, JL No. 100, under Mahatpur Gram Panchayat, Vill:- Tilakpur, Post:- Tilakpur, PS:- Chapra, Dist:- Nadia, Pin- 741164, West Bengal.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

1. All the Fire Safety Recommendations which was issued vide this Office Memo No FSR/0125186231000377, Dated:- 24/10/2023 be followed strictly at all time.
2. Driveway must have to be kept free of obstruction at all time for EASY movement of fire Appliances. No parking will be allowed on the driveway.
3. The interior finish decoration of building shall be made with low flame spread materiel confirming I.S. specification.
4. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the Building shall be strictly maintained.
5. Existing Electrical wiring of the whole building shall have to be carefully checked for any damage in wear and tear in them, particularly lines above false ceiling & ducts.
6. A fire control room including a close circuit T.V./ Monitor system will have to be installed which will observe all the floor of the Building.
7. The notice of Fire Fighting equipments and Evacuation plan shall be maintained and displayed at all venerable places of the Building.

8. The Employees and security staff shall be well conversant with installed Fire Fighting Equipments of the building and to operate in the event of Fire and Testing.
9. Mock Fire practice evacuation drill shall to be performed periodically with participant of all the occupants of the building.
10. Main and meter room shall be protected with Co2 or DCP Fire Extinguishers confirming I.S. Specifications.
11. First-Aid Fire Fighting system shall be provided as per I.S. Specification.
12. Arrangement shall have to be made for regular checking, testing and maintenance, of all the Fire Fighting installation of the Building to keep them in perfectly good working Condition at all the time.
13. If required the old line shall have to be replaced with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
14. Periodical Flashing of water in hydrants pipe line shall be made to maintain the efficient working performance of above mentioned system.
15. Fire Safety audit to be conducted at regular interval and to be recorded in the fire prevention maintenance register.
16. Transformer & switch Gear room (if applicable) shall be protected with CO2 or D.C.P. Fire Extinguisher conforming I.S. Specification.
17. Storage of volatile flammable liquid shall be prohibited and the handling of such liquids shall restricted to science Laboratory only.
18. If gas use in the laboratory shall be provided with an approve out side gas shut-off valve conspicuously marked.
19. Fire Licence shall have to be obtained from the licence section of the department for proposed storing of highly combustibile articles and procession with L.P.G., which come under purview of licence section as per Fire service Act-1950 (with up to date amendment).
20. This Fire Safety Certificate is valid for Three years and have to be renewed every three years interval from the date of Issue of this letter. In every three years Certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services, regarding the Performance of all the life & Fire Safety arrangements and installation of the Building.
21. Any deviation or changes the building in respect of the approved plan drawing, without prior permission from this office, this fire safety certificate will be treated cancelled automatically.

Signature Not Verified

Digitally Signed
Name: SUBRATA GUPTA
Date: 12-Nov-2023 06:05:54
Reason: Approved
Location: West Bengal

Divisional Fire Officer, Nadia Division, Nadia
West Bengal Fire & Emergency Services